

**Agency for Health Care Administration  
ASPEN: Regulation Set (RS)**

Printed 04/20/2015

Page 1 of 21

**Aspen State Regulation Set: K 8.01 Life Safety Code for Birth Ctr**

**ST - K0000 - INITIAL COMMENTS**

**Title** INITIAL COMMENTS

**Statute or Rule**

**Type** Memo Tag

**Regulation Definition**

**Interpretive Guideline**

These guidelines are meant solely to provide guidance to surveyors in the survey process.

**ST - K0300 - Other Standards**

**Title** Other Standards

**Statute or Rule** NFPA 101-2012 LSC

**Type** Rule

**Regulation Definition**

**Interpretive Guideline**

The facility shall meet the Standards of: NFPA 101, Life Safety Code, (2012 Edition), all reference documents per NFPA 101, Chapter 2, and applicable Florida State Fire Marshal's Rules and Regulations: 69A-3.012, Florida Administrative Code; 59A-11, Florida Administrative Code; 633.022, Florida Statutes; and the Florida Building Codes. Ambulatory Healthcare Facilities shall meet the provisions of NFPA 101, for (New), Chapters 38; or for (Existing), Chapters 39, as appropriate, whichever occupancy chapter provides the higher level of safety for any particular feature.

Agency for Health Care Administration  
ASPEN: Regulation Set (RS)

Printed 04/20/2015

Page 2 of 21

Aspen State Regulation Set: K 8.01 Life Safety Code for Birth Ctr

ST - K0301 - MULTIPLE OCCUPANCIES

**Title** MULTIPLE OCCUPANCIES

**Statute or Rule** NFPA 101-2012 LSC

**Type** Rule

**Regulation Definition**

All multiple occupancies shall be in accordance with 6.1.14 and 38.1.3 & 39.1.3.

Combined business occupancy and parking structure shall comply with 38.1.3.2 & 39.1.3.2.

NFPA 101 (2012) 38.1.3.1.1 & 39.1.3.1.1, 38.1.3.2.1, 38.1.3.2.2, 39.1.3.2.1, 39.1.3.2.2.

**Interpretive Guideline**

ST - K0302 - MEANS OF EGRESS

**Title** MEANS OF EGRESS

**Statute or Rule** NFPA 101-2012 LSC

**Type** Rule

**Regulation Definition**

All means of egress shall be in accordance with Chapter 7 and Chapter 38.2 & 39.2.

NFPA 101 (2012) 38.2.1.1 & 39.2.1.1.

**Interpretive Guideline**

ST - K0303 - DOORS IN MEANS OF EGRESS

**Title** DOORS IN MEANS OF EGRESS

**Statute or Rule** NFPA 101-2012 LSC

**Type** Rule

**Agency for Health Care Administration  
ASPEN: Regulation Set (RS)**

Printed 04/20/2015

Page 3 of 21

**Aspen State Regulation Set: K 8.01 Life Safety Code for Birth Ctr**

**Regulation Definition**

Doors in means of egress shall be in accordance with NFPA 101 (2012) 7.2.1.  
NFPA 101 (2012) 38.2.2.2.1 through 38.2.2.2.9 & 39.2.2.2.1 through 39.2.2.2.9.

**Interpretive Guideline**

**ST - K0304 - MEANS OF EGRESS COMPONENTS**

**Title** MEANS OF EGRESS COMPONENTS

**Statute or Rule** NFPA 101-2012 LSC

**Type** Rule

**Regulation Definition**

Stairs shall be in accordance with NFPA 101 (2012) 7.2.2  
Spiral stairs complying with 7.2.2.2.3 shall be permitted.  
NFPA 101 (2012) 38.2.2.3.1 through 38.2.2.3.2 & 39.2.2.3.1 through 39.2.2.3.3.

**Interpretive Guideline**

**ST - K0305 - EGRESS CAP, #EXITS, TRAVEL DISTANCE & DISCHRG**

**Title** EGRESS CAP, #EXITS, TRAVEL DISTANCE & DISCHRG

**Statute or Rule** NFPA 101-2012 LSC

**Type** Rule

**Regulation Definition**

Egress capacity, number of exits, travel distance, and discharge shall be in accordance with NFPA 101 (2012) 7.3 through 7.7.

**Interpretive Guideline**

NFPA 101 (2012) 38.2.3 through 38.2.7, 39.2.3 through 39.2.7.

Agency for Health Care Administration  
ASPEN: Regulation Set (RS)

Printed 04/20/2015

Page 4 of 21

Aspen State Regulation Set: K 8.01 Life Safety Code for Birth Ctr

ST - K0306 - EGRESS LIGHTING

**Title** EGRESS LIGHTING

**Statute or Rule** NFPA 101-2012 LSC

**Type** Rule

**Regulation Definition**

**Interpretive Guideline**

Means of egress shall be illuminated in accordance with Section 7.8.  
NFPA 101 (2012) 38.2.8 & 39.2.8.

ST - K0307 - EMERGENCY LIGHTING

**Title** EMERGENCY LIGHTING

**Statute or Rule** NFPA 101-2012 LSC

**Type** Rule

**Regulation Definition**

**Interpretive Guideline**

Emergency Lighting is in accordance with NFPA 101 (2012) 7.9.  
NFPA 101 (2012) 4.5.8.

ST - K0308 - EGRESS SIGNAGE

**Title** EGRESS SIGNAGE

**Statute or Rule** NFPA 101-2012 LSC

**Type** Rule

**Regulation Definition**

**Interpretive Guideline**

Means of egress shall have signs in accordance with Section 7.10.

**Agency for Health Care Administration  
ASPEN: Regulation Set (RS)**

Printed 04/20/2015

Page 5 of 21

**Aspen State Regulation Set: K 8.01 Life Safety Code for Birth Ctr**

NFPA 101 (2012) 38.2.10 & 39.2.10.

**ST - K0309 - VERTICAL OPENINGS**

**Title** VERTICAL OPENINGS

**Statute or Rule** NFPA 101-2012 LSC

**Type** Rule

**Regulation Definition**

**Interpretive Guideline**

Vertical openings shall be enclosed or protected in accordance with Section 8.6, unless otherwise permitted by any of the following:

- (1) Unenclosed vertical openings in accordance with 8.6.9.1 shall be permitted. (Existing or 39.2.4.7)
- (2) Exit access stairs in accordance with 38.2.4.6 & 39.2.4.6 shall be permitted to be unenclosed. (Existing or 39.2.4.7)
- (3) (Existing) Unprotected vertical openings shall be permitted in buildings complying with all of the following:
  - (a) Where protected throughout by an approved automatic sprinkler system in accordance with 9.7.1.1(1)
  - (b) Where no unprotected vertical opening serves as any part of any required means of egress
  - (c) Where required exits consist of exit doors that discharge directly to the finished ground level in accordance with 7.2.1, outside stairs in accordance with 7.2.2, smoke proof enclosures in accordance with 7.2.3, or horizontal exits in accordance with 7.2.4

NFPA 101 (2102) 38.3.1.2.1 & 39.3.1.2.1.

Floors that are below the street floor and are used for storage or other than business occupancy shall have no unprotected openings to business occupancy floors.

NFPA 101 (2012) 38.3.1.2 & 39.3.1.2.

**Agency for Health Care Administration  
ASPEN: Regulation Set (RS)**

Printed 04/20/2015

Page 6 of 21

**Aspen State Regulation Set: K 8.01 Life Safety Code for Birth Ctr**

**ST - K0310 - HAZARDOUS AREAS**

**Title** HAZARDOUS AREAS

**Statute or Rule** NFPA 101-2012 LSC

**Type** Rule

**Regulation Definition**

**Interpretive Guideline**

Hazardous areas shall be in accordance with NFPA 101 (2012)  
38.3.2 & 39.3.2, 8.7.

**ST - K0311 - INTERIOR FINISHES**

**Title** INTERIOR FINISHES

**Statute or Rule** NFPA 101-2012 LSC

**Type** Rule

**Regulation Definition**

**Interpretive Guideline**

Interior finishes shall be in accordance with NFPA 101 (2012)  
38.3.3.1 through 38.3.3.3.3 & 39.3.3.1 through 39.3.3.3.3,  
10.2.

**ST - K0312 - INTERIOR FLOOR CARPET FINISH**

**Title** INTERIOR FLOOR CARPET FINISH

**Statute or Rule** NFPA 101-2012 LSC

**Type** Rule

**Regulation Definition**

**Interpretive Guideline**

Carpet and carpet like interior floor finishes shall comply with  
ASTM D 2859, Standard Test Method for Ignition  
Characteristics of Finished Textile Floor Covering Materials.

**Agency for Health Care Administration**  
**ASPEN: Regulation Set (RS)**

Printed 04/20/2015

Page 7 of 21

**Aspen State Regulation Set: K 8.01 Life Safety Code for Birth Ctr**

NFPA 101 (2012) 10.2.7.1.

**ST - K0313 - FIRE ALARM**

**Title** FIRE ALARM

**Statute or Rule** NFPA 101-2012 LSC

**Type** Rule

**Regulation Definition**

**Interpretive Guideline**

Birth centers equipped with a fire alarm system shall be in accordance with NFPA 101 (2012) 38.3.4 & 39.3.4, 9.6.

**ST - K0314 - FIRE EXTINGUISHERS**

**Title** FIRE EXTINGUISHERS

**Statute or Rule** NFPA 101-2012 LSC

**Type** Rule

**Regulation Definition**

**Interpretive Guideline**

Portable fire extinguishers shall be provided in every business occupancy in accordance with 9.7.4.1.  
NFPA 101 (2012) 38.3.5 & 39.3.5.

**ST - K0315 - UTILITIES**

**Title** UTILITIES

**Statute or Rule** NFPA 101-2012 LSC

**Type** Rule

**Regulation Definition**

**Interpretive Guideline**

Utilities shall comply with the provisions of Section 9.1.

**Agency for Health Care Administration**  
**ASPEN: Regulation Set (RS)**

Printed 04/20/2015

Page 8 of 21

**Aspen State Regulation Set: K 8.01 Life Safety Code for Birth Ctr**

NFPA 101 (2012) 38.5.1 & 39.5.1.

**ST - K0316 - HVAC EQUIPMENT**

**Title** HVAC EQUIPMENT

**Statute or Rule** NFPA 101-2012 LSC

**Type** Rule

**Regulation Definition**

Heating, ventilating, and air-conditioning shall comply with the provisions of Section 9.2 and shall be installed in accordance with the manufacturer's specifications.

Air-conditioning, heating, ventilating ductwork, and related equipment shall be in accordance with NFPA 90A, Standard for the Installation of Air-Conditioning and Ventilating Systems, or NFPA 90B, Standard for the Installation of Warm Air Heating and Air-Conditioning Systems, unless such installations are approved existing installations, which shall be permitted to be continued in service.

NFPA 101 Life Safety Code (2012) 38.5.2 & 39.5.2, 9.2.1, NFPA 90A (2012) & NFPA 90B (2012).

**Interpretive Guideline**

**ST - K0317 - ELEVATORS**

**Title** ELEVATORS

**Statute or Rule** NFPA 101-2012 LSC

**Type** Rule

**Regulation Definition**

Elevators shall comply with the provisions of Section 9.4. An elevator, other than an elevator in accordance with 7.2.13, shall not be considered a component in a required means of egress but shall be permitted as a component in an accessible

**Interpretive Guideline**



**Agency for Health Care Administration  
ASPEN: Regulation Set (RS)**

Printed 04/20/2015

Page 9 of 21

**Aspen State Regulation Set: K 8.01 Life Safety Code for Birth Ctr**

means of egress.

Except as modified herein, new elevators shall be in accordance with the requirements of ASME A17.1/CSA B44, Safety Code for Elevators and Escalators.

Except as modified herein, existing elevators shall be in accordance with the requirements of ASME A17.3, Safety Code for Existing Elevators and Escalators.

Elevators in accordance with ASME A17.7/CSA B44.7, Performance-Based Safety Code for Elevators and Escalators, shall be deemed to comply with ASME A17.1/CSA B44, Safety Code for Elevators and Escalators, or ASME A17.3, Safety Code for Existing Elevators and Escalators.

For other than elevators used for occupant-controlled evacuation in accordance with Section 7.14 and other than existing elevators, the elevator corridor call station pictograph specified in 2.27.9 of ASME A17.1/CSAB44, Safety Code for Elevators and Escalators, shall be provided at each elevator landing.

All new elevators shall conform to the fire fighters ' emergency operations requirements of ASME A17.1/CSA B44, Safety Code for Elevators and Escalators.

All existing elevators having a travel distance of 25 ft (7620 mm) or more above or below the level that best serves the needs of emergency personnel for fire-fighting or rescue purposes shall conform to the fire fighters ' emergency operations requirements of ASMEA17.3, Safety Code for Existing Elevators and Escalators.

The number of elevator cars permitted in a hoist-way shall be in accordance with 8.6.9.4.

Elevator machine rooms that contain solid-state equipment for

**Agency for Health Care Administration**  
**ASPEN: Regulation Set (RS)**

*Printed 04/20/2015*

Page 10 of 21

**Aspen State Regulation Set: K 8.01 Life Safety Code for Birth Ctr**

elevators, other than existing elevators, having a travel distance exceeding 50 ft (15 m) above the level of exit discharge, or exceeding 30 ft (9.1 m) below the level of exit discharge, shall be provided with independent ventilation or air-conditioning systems to maintain temperature during fire fighters' emergency operations for elevator operation (see 9.4.3). The operating temperature shall be established by the elevator equipment manufacturer's specifications. When standby power is connected to the elevator, the machine room ventilation or air-conditioning shall be connected to standby power.

Elevators shall be subject to periodic inspections and tests as specified in ASME A17.1/CSA B44, Safety Code for Elevators and Escalators.

All elevators equipped with fire fighters' emergency operations in accordance with 9.4.3 shall be subject to a monthly operation with a written record of the findings made and kept on the premises as required by ASME A17.1/CSA B44, Safety Code for Elevators and Escalators.

The elevator inspections and tests required by 9.4.6.1 shall be performed at frequencies complying with one of the following:

- (1) Inspection and test frequencies specified in Appendix N of ASME A17.1/CSA B44, Safety Code for Elevators and Escalators
- (2) Inspection and test frequencies specified by the authority having jurisdiction

Elevators serving various stories of a building shall not open to an exit enclosure.

NFPA 101 (2012) 38.5.3 & 39.5.3, 9.4.1 thru 9.4.7.

Agency for Health Care Administration  
ASPEN: Regulation Set (RS)

Printed 04/20/2015

Page 11 of 21

Aspen State Regulation Set: K 8.01 Life Safety Code for Birth Ctr

ST - K0318 - EXTINGUISHER TRAINING

**Title** EXTINGUISHER TRAINING

**Statute or Rule** NFPA 101-2012 LSC

**Type** Rule

**Regulation Definition**

**Interpretive Guideline**

Portable fire extinguisher staff training shall be conducted periodically.

NFPA 101 (2012) 38.7.3 & 39.7.3.

ST - K0319 - UNOBSTRUCTED EGRESS

**Title** UNOBSTRUCTED EGRESS

**Statute or Rule** NFPA 101-2012 LSC

**Type** Rule

**Regulation Definition**

**Interpretive Guideline**

In every occupied building or structure, means of egress from all parts of the building shall be maintained free and unobstructed. Means of egress shall be accessible to the extent necessary to ensure reasonable safety for occupants having impaired mobility.

NFPA 101 (2012) 4.5.3.2.

ST - K0320 - EXISTING LIFE SAFETY FEATURES

**Title** EXISTING LIFE SAFETY FEATURES

**Statute or Rule** NFPA 101-2012 LSC

**Type** Rule

**Agency for Health Care Administration**  
**ASPEN: Regulation Set (RS)**

Printed 04/20/2015

Page 12 of 21

**Aspen State Regulation Set: K 8.01 Life Safety Code for Birth Ctr**

**Regulation Definition**

Existing life safety features obvious to the public, if not required by the Code, shall be either maintained or removed.

NFPA 101 (2012) 4.6.12.3.

**Interpretive Guideline**

**ST - K0321 - AUTOMATIC FIRE SPRINKLER SYSTEM**

**Title** AUTOMATIC FIRE SPRINKLER SYSTEM

**Statute or Rule** NFPA 101-2012 LSC

**Type** Rule

**Regulation Definition**

Birth centers equipped with an automatic fire sprinkler system shall be in accordance with NFPA 101 (2012) 4.6.12.4, 9.7.

**Interpretive Guideline**

**ST - K0322 - DECORATIONS AND FURNISHING**

**Title** DECORATIONS AND FURNISHING

**Statute or Rule** NFPA 101-2012 LSC

**Type** Rule

**Regulation Definition**

Decorations and furnishings that do not meet the definition of interior finish, as defined in 3.3.90.2, shall be regulated by the provisions of Section 10.3.

NFPA 101 (2012) 10.2.4.5.

**Interpretive Guideline**

**Agency for Health Care Administration  
ASPEN: Regulation Set (RS)**

Printed 04/20/2015

Page 13 of 21

**Aspen State Regulation Set: K 8.01 Life Safety Code for Birth Ctr**

**ST - K0323 - MAINTENANCE, INSPECTION, AND TESTING**

**Title** MAINTENANCE, INSPECTION, AND TESTING

**Statute or Rule** NFPA 101-2012 LSC

**Type** Rule

**Regulation Definition**

Whenever or wherever any device, equipment, system, condition, arrangement, level of protection, fire-resistive construction, or any other feature is required for compliance with the provisions of this Code, such device, equipment, system, condition, arrangement, level of protection, fire-resistive construction, or other feature shall thereafter be continuously maintained. Maintenance shall be provided in accordance with applicable NFPA requirements or requirements developed as part of a performance-based design, or as directed by the authority having jurisdiction.

Any device, equipment, system, condition, arrangement, level of protection, fire-resistive construction, or any other feature requiring periodic testing, inspection, or operation to ensure its maintenance shall be tested, inspected, or operated as specified elsewhere in this Code or as directed by the authority having jurisdiction.

Maintenance, inspection, and testing shall be performed under the supervision of a responsible person who shall ensure that testing, inspection, and maintenance are made at specified intervals in accordance with applicable NFPA standards or as directed by the authority having jurisdiction.

NFPA 101 (2012) 4.6.12.1 & 4.6.12.4 & 4.6.12.5.

**Interpretive Guideline**

**Agency for Health Care Administration  
ASPEN: Regulation Set (RS)**

Printed 04/20/2015

Page 14 of 21

**Aspen State Regulation Set: K 8.01 Life Safety Code for Birth Ctr**

**ST - K0324 - COOKING EQUIPMENT**

**Title** COOKING EQUIPMENT

**Statute or Rule** F.A.C. 59A-11.024; NFPA 101-20121 LSC

**Type** Rule

**Regulation Definition**

Birth centers, with four or more birthing rooms, and in which food is provided to the clients shall comply with the prescribed equipment pursuant to Chapter 64E-11, F.A.C.

F.A.C. 59A-11.024(3)

Cooking equipment shall be protected in accordance with 9.2.3, unless the cooking equipment is one of the following types:

- (1) Outdoor equipment
- (2) Portable equipment not flue-connected
- (3) Equipment used only for food warming

NFPA 101 (2012) 38.3.2.3 & 39.3.2.3, 9.2.3.

**Interpretive Guideline**

**ST - K0325 - FOOD SERVICE**

**Title** FOOD SERVICE

**Statute or Rule** F.A.C. 59A-11; F.A.C. 64E-11

**Type** Rule

**Regulation Definition**

In birth centers where food is provided to the clients:

- (1) All food service areas shall comply with Chapter 64E-11, F.A.C.
- (2) Birth centers with three or less birthing rooms shall have

**Interpretive Guideline**

**Agency for Health Care Administration**  
**ASPEN: Regulation Set (RS)**

Printed 04/20/2015

Page 15 of 21

**Aspen State Regulation Set: K 8.01 Life Safety Code for Birth Ctr**

facilities and equipment that is consistent with those found in single family dwelling units.

(3) Birth centers, with four or more birthing rooms, and in which food is provided to the clients shall comply with the prescribed equipment pursuant to Chapter 64E-11, F.A.C.

(4) If food is catered from outside sources, those sources must comply with Chapter 64E-11, F.A.C.

(5) If the birth center policy limits the food service to light snacks supplied by the client or support persons there shall be an adequate refrigerator capable of maintaining a temperature of 45 degrees Fahrenheit or lower.

F.A.C. 59A-11.024

Approved local exhaust ventilation shall be installed at or over all cooking units such as ranges, griddles, deep-fat frying units and other units of equipment which release appreciable quantities of steam, odors, grease or smoke.

F.A.C. 64E-11.006(1)(g)

Ventilation hoods and devices shall be designed to prevent grease or condensation from collecting on walls and ceilings and from dripping into food or onto food-contact surfaces. Filters or other grease extracting equipment, if used, shall be readily removable for cleaning and replacement if not designed to be cleaned in place.

F.A.C. 64E-11.006(2)(q)

**ST - K0326 - DISASTER PLAN**

**Title** DISASTER PLAN

**Statute or Rule** F.A.C. 59A-11

**Type** Rule

Agency for Health Care Administration  
ASPEN: Regulation Set (RS)

Printed 04/20/2015

Page 16 of 21

Aspen State Regulation Set: K 8.01 Life Safety Code for Birth Ctr

**Regulation Definition**

Each birth center shall develop a written disaster plan which shall be rehearsed by personnel at least twice a year and shall cover internal casualty producing incidents. The plan shall include provisions for complete evacuation of the facility during an actual disaster.

F.A.C. 59A-11.027

**Interpretive Guideline**

ST - K0327 - EQUIPMENT SAFETY

**Title** EQUIPMENT SAFETY

**Statute or Rule** F.A.C. 59A-11

**Type** Rule

**Regulation Definition**

Equipment shall be clean and free from safety hazards and in sufficient supply to meet the needs of the clients and staff.

F.A.C. 59A-11.028(1)

**Interpretive Guideline**

ST - K0328 - OXYGEN SAFETY

**Title** OXYGEN SAFETY

**Statute or Rule** F.A.C. 59A-11

**Type** Rule

**Regulation Definition**

Oxygen shall be stored in a clean dry place with no flammable materials or machinery capable of producing sparks in the immediate vicinity. Oxygen supplies shall be purchased from a licensed dealer.

**Interpretive Guideline**



Agency for Health Care Administration  
ASPEN: Regulation Set (RS)

Printed 04/20/2015

Page 17 of 21

Aspen State Regulation Set: K 8.01 Life Safety Code for Birth Ctr

F.A.C. 59A-11.028(4)

ST - K0329 - FIRE PLAN/DRILLS/LOCAL AHJ INSP/FIRE EXT SVC

**Title** FIRE PLAN/DRILLS/LOCAL AHJ INSP/FIRE EXT SVC

**Statute or Rule** F.A.C. 59A-11

**Type** Rule

**Regulation Definition**

**Interpretive Guideline**

Fire Control. Each birth center shall provide fire protection through the adoption of written fire control plans rehearsed four times a year by all personnel.

(a) To safeguard all clients, the birth center shall have:

1. Written evidence of regular inspection by local fire control agencies;
2. Annual check of fire extinguishers for type, replacement, and renewal dates.

F.A.C. 59A-11.023(9).

ST - K0330 - PHYSICAL ENVIRONMENT & WATER SUPPLY

**Title** PHYSICAL ENVIRONMENT & WATER SUPPLY

**Statute or Rule** F.A.C. 59A-11

**Type** Rule

**Regulation Definition**

**Interpretive Guideline**

All birth centers shall comply with all design and construction standards for birth centers as required by the Florida Building Code.

Laundry:

- (a) Where laundry facilities are provided, clean clothing, bed linens, and towels shall be available for the patients.
- (b) Carts used for transporting dirty clothes, linens, and towels

**Agency for Health Care Administration**  
**ASPEN: Regulation Set (RS)**

Printed 04/20/2015

Page 18 of 21

**Aspen State Regulation Set: K 8.01 Life Safety Code for Birth Ctr**

shall not be used for transporting clean articles unless they have been thoroughly cleaned.

(c) If laundry facilities are not available, sheets and blankets shall be cleaned by commercial laundries.

**Bedding:**

Beds and beddings shall be kept in good repair, cleaned and sanitized whenever soiled. Mattresses and pillows shall have cleanable covers which shall be cleaned and sanitized between use by different clients. Clean sheets shall be used for each client. Blankets shall be washed or dry cleaned whenever soiled. Sheets, blankets, and clean clothing shall be stored in a clean, dry place between laundering and use.

**Insect and Rodent Control:**

All pesticides used to control insects or rodents shall be applied as required by the label directions for use and as required by Chapter 482, F.S.

**Poisonous or Toxic Substances:**

Poisonous or toxic compounds are to be stored apart from food and other areas that would constitute a hazard to the residents.

**Water Supply:**

Water supplies shall be adequate to serve the demands of the facility and shall be constructed, operated and maintained as required by Chapter 62-555 or 64E-8, F.A.C.

**Sewage Disposal:**

(a) All sewage and liquid waste shall be disposed of in manners as required by Chapter 62-600 or 64E-6, F.A.C.

**Waste Disposal:**

(a) All garbage, trash and rubbish from residential areas shall be collected daily and taken to storage facilities. Garbage shall

**Agency for Health Care Administration  
ASPEN: Regulation Set (RS)**

Printed 04/20/2015

Page 19 of 21

**Aspen State Regulation Set: K 8.01 Life Safety Code for Birth Ctr**

be removed from storage frequently enough to prevent a potential hazard or at least twice per week. Wet garbage shall be collected and stored in impervious, leak proof, fly tight containers pending disposal. All containers, storage areas and surrounding premises shall be kept clean and free of vermin. (b) If public or contract garbage collection service is available, the facility shall subscribe to these services unless the volume makes on-site disposal feasible. If garbage and trash are disposed of on premises, the method of disposal shall be operated in a manner as required by Chapter 62-701, F.A.C.

F.A.C. 59A-11.023(1-8).

**ST - K0331 - ALCOHOL BASED HAND RUB DISPENSERS**

**Title** ALCOHOL BASED HAND RUB DISPENSERS

**Statute or Rule** NFPA 101-2012 LSC

**Type** Rule

**Regulation Definition**

Alcohol-based hand-rub dispensers shall be protected in accordance with 8.7.3.1, unless all of the following conditions are met:

- (1) Where dispensers are installed in a corridor, the corridor shall have a minimum width of 6 ft (1830 mm).
- (2) The maximum individual dispenser fluid capacity shall be as follows:
  - (a) 0.32 gal (1.2 L) for dispensers in rooms, corridors, and areas open to corridors
  - (b) 0.53 gal (2.0 L) for dispensers in suites of rooms
- (3) Where aerosol containers are used, the maximum capacity of the aerosol dispenser shall be 18 oz (0.51 kg) and shall be limited to Level 1 aerosols as defined in NFPA30B, Code for the Manufacture and Storage of Aerosol Products.
- (4) Dispensers shall be separated from each other by horizontal spacing of not less than 48 in. (1220 mm).

**Interpretive Guideline**

**Agency for Health Care Administration**  
**ASPEN: Regulation Set (RS)**

Printed 04/20/2015

Page 20 of 21

**Aspen State Regulation Set: K 8.01 Life Safety Code for Birth Ctr**

(5) Not more than an aggregate 10 gal (37.8 L) of alcohol based hand-rub solution or 1135 oz (32.2 kg) of Level 1 aerosols, or a combination of liquids and Level 1 aerosols not to exceed, in total, the equivalent of 10 gal (37.8 L) or 1135 oz (32.2 kg), shall be in use outside of a storage cabinet in a single smoke compartment, except as otherwise provided in 20.3.2.6(6).

(6) One dispenser per room complying with 20.3.2.6 (2) or (3), and located in the room, shall not be required to be included in the aggregated quantity specified in 20.3.2.6(5).

(7) Storage of quantities greater than 5 gal (18.9 L) in a single smoke compartment shall meet the requirements of NFPA 30, Flammable and Combustible Liquids Code.

(8) Dispensers shall not be installed in the following locations:

(a) Above an ignition source within a 1 in. (25 mm) horizontal distance from each side of the ignition source

(b) To the side of an ignition source within a 1 in. (25mm) horizontal distance from the ignition source

(c) Beneath an ignition source within a 1 in. (25 mm) vertical distance from the ignition source

(9) Dispensers installed directly over carpeted floors shall be permitted only in sprinklered smoke compartments.

(10) The alcohol-based hand-rub solution shall not exceed 95 percent alcohol content by volume.

(11) Operation of the dispenser shall comply with the following criteria:

(a) The dispenser shall not release its contents except when the dispenser is activated, either manually or automatically by touch-free activation.

(b) Any activation of the dispenser shall occur only when an object is placed within 4 in. (100 mm) of the sensing device.

(c) An object placed within the activation zone and left in place shall not cause more than one activation.

(d) The dispenser shall not dispense more solution than the amount required for hand hygiene consistent with label

**Agency for Health Care Administration**  
**ASPEN: Regulation Set (RS)**

Printed 04/20/2015

Page 21 of 21

**Aspen State Regulation Set: K 8.01 Life Safety Code for Birth Ctr**

instructions.

(e) The dispenser shall be designed, constructed, and operated in a manner that ensures that accidental or malicious activation of the dispensing device is minimized.

(f) The dispenser shall be tested in accordance with the manufacturer ' s care and use instructions each time a new refill is installed.

NFPA 101 (2012) 4.6.12.1.

**ST - K0332 - Other Standards Not Previously Listed**

**Title** Other Standards Not Previously Listed

**Statute or Rule** NFPA 101-2012 LSC

**Type** Rule

**Regulation Definition**

**Interpretive Guideline**

OTHER LSC Standards not previously listed. (Code Reference and Text shall be provided.)